# Arrow Hart weather resistant and tamper & weather resistant receptacles

Project Name:	Prepared By:
Project Number:	Date:
Catalog Number:	Type:

# **Description**

2 pole, 3-wire grounding 15A, 125V/AC 20A, 125V/AC





WRBR15





TWR270



**Design features** 

- Provides compliance with 2017 NEC® Article 406.9 that states that all receptacles installed in wet and damp locations must be weather resistant
- Manufactured with the highest grade materials; durable impactresistant thermoplastic face and back body is virtually unbreakable
- "TR" designation provides visual identification that device has tamper resistant shutters preventing insertion of foreign objects
- "WR" indentifer quickly indicates during inspections that a weather resistant receptacle has been installed
- · Terminal screws are backed out and ready to wire
- Extra-long and extra-wide mounting straps
- Patented built-in wire stripper for #14 and #12 wire to speed installation
- Side-wire terminals accept up to #10 solid or stranded wire
- Push-in terminals accept #14 solid wire (TWR270 duplex devices only)

Table 1. TWR residential grade

				Rating		
Catalog no.	Description	Α	V/AC	NEMA	Color suffix	
□ TWR270	Dunlex recentacle	15	125	5-15B	GY I A V W	

Table 2. WR & TWR specification grade GFCI

Rating						
	Catalog no.	Description	Α	V/AC	NEMA	Color suffix
	☐ WRSGF15	Duplex GFCI	15	125	5-15R	B, GY, V, W
	☐ WRSGF20	Duplex GFCI	20	125	5-20R	B, BK, GY, V, W
	☐ TWRSGF15	Duplex GFCI	15	125	5-15R	B, GY, LA, V, W
	☐ TWRSGF20	Duplex GFCI	20	125	5-20R	B, GY, LA, V ,W

Table 3. WR & TWR commercial grade receptacle

		Ra	ting		
Catalog no.	Description	Α	V/AC	NEMA	Color suffix
☐ WRBR15	Duplex receptacle	15	125	5-15R	B, V, W
☐ WRBR20	Duplex receptacle	20	125	5-20R	B, V, W
☐ TWRBR15	Duplex receptacle	15	125	5-15R	B, GY, V, W
☐ TWRBR20	Duplex receptacle	20	125	5-20R	B, V, W

Table 4. WR & TWR commercial grade receptacle

		Ra	ting		
Catalog no.	Description	Α	V/AC	NEMA	Color suffix
□ WRSGF15F	Duplex GFCI	15	125	5-15R	B, GY, V, W
□ WRSGF20F	Duplex GFCI	20	125	5-20R	B, GY, V, W
☐ TWRSGF15F	Duplex GFCI	15	125	5-15R	B, GY, LA, V, W
☐ TWRSGF20F	Duplex GFCI	20	125	5-20R	B, GY, LA, V, W



Project Name:	Prepared By:
Project Number:	Date:
Catalog Number:	Type:

# **Applications**

Weather resistant receptacles are constructed of enhanced nylon and corrosion resistant metal components for use in damp and wet locations. Installing these receptacles properly in an approved weather protective cover ensures compliance with 2017 NEC Article 406.9. Tamper and weather resistant receptacles add a UL listed safety shutter system that prevents the insertion of foreign objects into receptacles to the weather resistant devices. Installing these receptacles properly in an approved weather protective cover ensures compliance with 2017 NEC Article 406.9 and 406.12. Areas of application include: residential decks, porches, patios, garages and yards; commercial convenience outlets in damp or wet areas; residential, multi-family or commercial dwelling units; residential, multi-family or commercial pool and spa areas; indoor or outdoor public facilities and recreation areas.

Table 5. Specifications

Catalog no.	TWR270 series	WRSGF series	TWRSGF series	WRBR series	TWRBR series	WRSGFF series	TWRSGFF series
Receptacle type	Tamper & weather resistant residential grade duplex	Weather resistant specification grade GFCI	Tamper & weather resistant specification grade GFCI	Weather resistant commercial grade duplex	Tamper & weather resistant commercial grade duplex	Weather resistant specification grade GFCI NAFTA	Tamper & weather resistant specification GFCI NAFTA
Wiring type	Push & side wire	Back & side wire	Back & side wire	Back & side wire	Back & side wire	Back & side wire	Back & side wire
Testing & code compliance	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     NOM/ANSI certified	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     Meets all UL943 (GFCI) and UL498 (receptacles) requirements     NOM/ANSI certified	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     Meets all UL943 (GFCI) and UL498 (receptacles) requirements     NOM/ANSI certified	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     UL verified to Fed. Spec. WC-596G     NOM/ANSI certified	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     UL verified to Fed. Spec. WC-596G     NOM/ANSI certified	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     Meets all UL943 (GFCI) and UL498 (receptacles) requirements     NOM/ANSI certified     NAFTA compliant	cULus Listed to UL498     UL certified to CSA C22.2, no. 42     Meets all UL943 (GFCI) and UL498 (receptacles) requirements     NOM/ANSI certified     NAFTA compliant
Environmental specifications	UL 94 requirements; V0 rated	UL 94 requirements; V2 rated <b>Temperature rating:</b>	UL 94 requirements; V2 rated <b>Temperature rating:</b>	UL 94 requirements; V2 rated <b>Temperature rating:</b>	Flammability: Meets UL 94 requirements; V2 rated Temperature rating: -20°C to 70°C (-4°F to 158°F)	Flammability: Meets UL 94 requirements; V2 rated Temperature rating: -35°C to 66°C (-31°F to 150.8°F)	Flammability: Meets UL 94 requirements; V2 rated Temperature rating: -35°C to 66°C (-31°F to 150.8°F)
Electrical specifications	Dielectric voltage: Withstands 2000V per UL 498 Current interrupt- ing: Yes, at full-rated current Temperature rise: Max. 30°C (86°F) after 100 cycles of overload	Dielectric voltage: Withstands 2000V per UL 498 Current interrupt- ing: Yes, at full-rated current Temperature rise: Max. 30°C (86°F) after 100 cycles of overload	Dielectric voltage: Withstands 2000V per UL 498 Current interrupt- ing: Yes, at full-rated current Temperature rise: Max. 30°C (86°F) after 100 cycles of overload	per UL 498 <b>Current</b> <b>interrupting:</b> Yes, at full-rated current <b>Temperature rise:</b> Standard - max. 30°C (86°F) after 250 cycles of overload @	UL 498 Current interrupting: Yes, at full-rated current Temperature rise: Standard - max. 30°C		Dielectric voltage: Withstands 2000V per UL 498 Current interrupting: Yes, at full-rated current Temperature rise: Max. 30°C (86°F) after 100 cycles of overload
Mechanical specifications	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device	Terminal accommodation: #14 - 10 AWG Voltage ratings: Permanently marked on device

Table 6. Materials

Catalog no.	TWR270 series	WRSGF series	TWRSGF series	WRBR series	TWRBR series
Body top	Thermoplastic, PVC	Thermoplastic, nylon 6/6	Thermoplastic, nylon 6/6	Thermoplastic, nylon 6/6	Thermoplastic, nylon
Body bottom	Thermoplastic, PVC	Thermoplastic, PVC	Thermoplastic, PVC	Thermoplastic, PVC	Thermoplastic, nylon
Strap	Nickel plated steel				
Contacts	Brass alloy				
Terminal screws	Brass/nickel plated stainless steel				
Terminal clamps	N/A	Nickel plated steel	Nickel plated steel	Nickel plated steel	Nickel plated steel

# Arrow Hart weather resistant and tamper & weather resistant receptacles

Project Name:	Prepared By:
Project Number:	Date:
Catalog Number:	Type:

#### Table 7. GFCI status indicator

Test indicator RED LED	Test indicator AMBER LED	Diagnosis	Action suffix
OFF	OFF	Device is functioning properly OR branch circuit may have no power	Manually depress TEST button to trip device. <b>Amber</b> light should come ON  If <b>Amber</b> light does <u>not</u> come ON, check if there is power to the branch  If <b>Amber</b> light does come ON, manually depress the RESET button to restore power to the device  If GFCI does not reset, replace GFCI  If GFCI does reset, device is functioning properly
OFF	ON	Device is in tripped state	Manually depress the RESET button to restore power to the device  • If GFCI does not reset, replace GFCI
Blinking	OFF	Device's "end of life" indication OR device is in reset state	Manually depress TEST button to trip device. <b>Amber</b> light should come ON  If <b>Amber</b> light does <u>not</u> come ON, check if there is power to the branch  If <b>Amber</b> light does come ON, manually depress the RESET button to restore power to the device  If it does not reset, and/or the blinking continues, replace GFCI
Blinking	ON	Device's "end of life" indication OR device is in tripped state	Manually depress the RESET button to restore power to the device  If it does not reset, and/or the blinking continues, replace GFCI

#### Table 8. Color ordering information

For ordering devices, include Cat. no. followed by the color code: B (Brown), BK (Black), GY (Gray), LA (Light Almond), V (Ivory), W (White)



### **Product dimensions**




Figure 1. WRSGF15 Line art with dimensions




Figure 2. WRSGF20 Line art with dimensions

· ·		Prepared By:
		Date:
	Catalog Number:	Type:

## **Product dimensions**




Figure 3. TWRSGF15 Line art with dimensions




Figure 4. TWRSGF20 Line art with dimensions

# Arrow Hart weather resistant and tamper & weather resistant receptacles

Project Name:	Prepared By:
Project Number:	Date:
Catalog Number:	Type:

# **Certifications & compliances**

Catalog No.	¢ <b>(UL</b> )⊌s	F (l) S	4	NOM 426	<b>F</b>	$\triangleright$	$\checkmark$
TWR270	•			•	٠		
WRSGF15	•		•	•	•		
WRSGF20	•			•	•		
TWRSGF15	•			•	•	•	
TWRSGF20	•			•	•	•	
WRBR15	•	•		•	•		•
WRBR20	•	•		•	•		•
TWRBR15	•	•	•	•	•		•
TWRBR20	•	•		•	•		•
WRSGF15F			•			•	•
WRSGF20F			•			•	•
TWRSGF15F			•			•	•
TWRSGF20F			•			•	•
						-	

**KEY:** ••••• cULus Fest Spec → NAFTA NOM → ArrowLink ® Build-To-Spec ⊗ ROHS

Parts are manufactured and designed in accordance with article 4 of the European Union's RoHS2 directive 2011/65/EU

Build-To-Spec Customizable Devices

Compliances, specifications and availability are subject to change without notice.

Electrical Sector 203 Cooper Circle Peachtree City, GA 30269 United States Eaton.com Eaton.com/arrowhart Electrical Sector Canada Operations 5925 McLaughlin Road Mississauga, Ontario, L5R 1B8 Canada EatonCanada.ca Eaton.com/arrowhart Electrical Sector Mexico Operations Carr. Tlalnepantla -Cuautitlán Km 178 s/n Col. Villa Jardín esq. Cerrada 8 de Mayo Cuautitlán, México CP 54800 México Eaton.mx Eaton.com/arrowhart

