

RAYNTITE®

TWO-GANG DEVICE COVER

Cubierta de Perforación

Doble Rayntite®

Couvercle pour Boîte

Double Rayntite®

GENERAL INSTRUCTIONS

IMPORTANT: Mount cover with hinge on top.

1. Turn off power.
2. Use only copper wire.
3. Remove appropriate device cutout on gasket.
4. Center cover gasket evenly.
5. Install mounting screws(provided).
6. Use caulking around cover if not mounted to a U.L. listed wet locations box.
7. Installation and wiring must comply with local electrical codes.

NOTE: If mounting to box, drill out (4) 5/32" holes in drill spots on plate before assembly.


INSTRUCCIONES AL DORSO
INSTRUCTIONS AU DOS

HUBBELL ELECTRICAL PRODUCTS
DIVISION OF HUBBELL INCORPORATED (DELAWARE)
P.O. BOX 4002 SOUTH BEND INDIANA 46634
CANADA 870 BROCK RD. S. PICKERING, ON L1W 1Z8
MADE IN INDIA / HECHO EN INDIA / FAIT AU INDIA

5040-0



0 50169 50400 0



Single 1.406" / GFCI Receptacles
Única de 1.406" / Toma corriente GFCI
Simple de 1.406 po / Prise M.A.L.T.

LISTED 731A
FLUSH DEVICE COVER
WET LOCATIONS
WITH COVER CLOSED

LISTADA 731A
TAPA PARA
DISPOSITIVO AL RAS
SITIOS MOJADOS CON
LA TAPA CERRADA

ENREGISTRER 731A
COUVERCLE DE
DISPOSITIF AFFLEURANT
ENDROITS MOUILLÉS SI
LE COUVERCLE EST FERMÉ



LISTED